



Emergency Service Notes

1. These are standard notes that are consistent for all our reviews. All notes shall be added to the plan to maintain adherence to general safety and construction regulations, which include, but are not limited to:

- i. The design and construction of all building systems that may affect emergency services shall be coordinated with the Township Fire Marshal's Office. (i.e., Fire Department Connections, Fencing or other barriers, Internal evac plans).
- ii. The property and all lots shall always be marked and readily identifiable for public safety and inspection purposes.
- iii. The marketing name of any development shall be submitted and approved by the Fire Marshal's Office.
- iv. Burning of refuse and construction debris is prohibited.
- v. Please furnish the name and contact information of the owner's representative who will assume the role of Fire Prevention Program Superintendent; subsequently, please contact the office so we can meet with them and review their Emergency Plan.
- vi. If there are any chains and/or gates utilized for security or other purposes, during construction, they shall be secured in an approved fashion and shall be approved by the Township Fire Marshal's Office.
- vii. If smoking is permitted on the grounds, designated smoking areas shall be established and posted.
- viii. A means of contacting 9-1-1, in the event of an emergency, shall be provided and maintained.
- ix. All procedures for fire protection during construction shall be in accordance with the 2015 International Fire Code, Chapter 33 (Fire Safety During Construction and Demolition).
- x. Submit a completed Emergency Contact Information Form.
- xi. Alerting, Notification, and Suppression Permits shall be submitted, as applicable, in addition to any requirements established by the Code Services Department.
- xii. Where required a Knox Box shall be installed. The location will be determined by the Fire Marshal's Office.
- xiii. Any exterior security gates and/or emergency access gates or chains that are part of the finished project shall be fitted with a Knox Box Pad Lock.
- xiv. If there will be an Emergency Access Road or a trail that doubles as an Emergency Access Road that is part of the finished project, there shall be bollards installed at each end of the access road. These bollards shall meet Limerick Township's specifications, which can be found on the Township's website, or a copy can be provided to you from the Township.